

**OUR CERTIFICATIONS**



**A2**



**THOMAS BELL-WRIGHT INTERNATIONAL CONSULTANTS**

Test Reference No.: XE070-2

**10. SUMMARY OF RESULTS**

The non-loadbearing 4mm thick Alstone FR A2 Aluminium Composite Panel (ACP) cladding assembly installed on 200mm thick masonry blocks has been evaluated in accordance with ASTM E119-20; Standard Test Methods for Fire Tests of Building Construction and Materials and ASTM E2226-15b; Standard Practice for Application of Hose Stream.

The requirements of the standards were satisfied for:

<b>FIRE RESISTANCE RATING</b>
<b>180 MINUTES</b>

This report and all records of the test to which it relates may not be retained by TBWIC beyond 5 years from the date of testing. This test report is respectfully submitted by: Thomas Bell-Wright International Consultants

Prepared By:

Reviewed & Authorized By:


Kevin A. Zachariah  
Senior Fire Testing Engineer



Dajsan Dippi, AlFireE  
Fire Testing Manager

**Report Revision Tracking**

Revision No.	Date Issued	Notes & Amendments
Rev. 00	12-Jun-23	This is the first issue of the report. No revisions are included.



**FR**



**THOMAS BELL-WRIGHT INTERNATIONAL CONSULTANTS**

Test Reference No.: XE070-1

**10. SUMMARY OF RESULTS**

The non-loadbearing 4mm thick Alstone FR B Aluminium Composite Panel (ACP) cladding assembly installed on 200mm thick masonry blocks has been evaluated in accordance with ASTM E119-20; Standard Test Methods for Fire Tests of Building Construction and Materials and ASTM E2226-15b; Standard Practice for Application of Hose Stream.

The requirements of the standards were satisfied for:

<b>FIRE RESISTANCE RATING</b>
<b>120 MINUTES</b>

This report and all records of the test to which it relates may not be retained by TBWIC beyond 5 years from the date of testing. This test report is respectfully submitted by: Thomas Bell-Wright International Consultants

Prepared By:

Reviewed & Authorized By:

Kevin A. Zachariah  
Senior Fire Testing Engineer



Dajsan Dippi, AlFireE  
Fire Testing Manager

**Report Revision Tracking**

Revision No.	Date Issued	Notes & Amendments
Rev. 00	12-Jun-23	This is the first issue of the report. No revisions are included.