



**BUREAU
VERITAS**

Test Order /Report No.BVIPL/ SPL:KL/729/9/2020

Date of Receipt: 09-09-2020

Date: 11-09-2020

Page:3

ASTRON CONCRETE PRODUCTS

Building.No 15/468,Kaipoorikkaramarampally P.O, Aluva, Ernakulam Dt.,Pin-683105

TEST REPORT ON COVER BLOCK SAMPLES

Source of sample for testing : Sample supplied by the customer.
Customer's Reference : Letter Dated:12-08-2020
UN : 20018872
Project# : Not Furnished
No of Sample# : 3
Date of test : 10-09-2020
Condition of samples : Satisfactory
Test Method : Laboratory Developed Method.

LOAD TEST:

Sl. No.	Identification#	Breaking Load (KN)
1	40 MM	10.1
2	40 MM	8.2
3	40 MM	8.4

#As furnished by the customer.

- Note:**
1. The results relate only to the items tested.
 2. Report shall not be reproduced except in full, without the written approval of the lab.
 3. Any correction invalidates this report.

for **BUREAUVERITAS (INDIA) PRIVATE LIMITED**
Construction Services Laboratory

For Bureau Veritas (India) Pvt. Ltd. *****

Authorised Signatory

