



**BUREAU  
VERITAS**

Test Order /Report No.BVIPL/ SPL:KL/729/9/2020  
Date of Receipt: 09-09-2020

Date: 11-09-2020  
Page:4

**ASTRON CONCRETE PRODUCTS**  
Building.No 15/468,Kaipoorikkaramarampally P.O, Aluva, Ernakulam Dt.,Pin-683105

**TEST REPORT ON COVER BLOCK SAMPLES**

Source of sample for testing : Sample supplied by the customer.  
Customer's Reference : Letter Dated:12-08-2020  
UIN : 20018872  
Project# : Not Furnished  
No of Sample# : 3  
Date of test : 10-09-2020  
Condition of samples : Satisfactory  
Test Method : Laboratory Developed Method.

**LOAD TEST:**

Sl. No.	Identification#	Breaking Load (KN)
1	100 MM	13.7
2	100 MM	10.6
3	100 MM	17.6

#As furnished by the customer.

**Note:** 1. The results relate only to the items tested.  
2. Report shall not be reproduced except in full, without the written approval of the lab.  
3. Any correction invalidates this report.

for **BUREAUVERITAS (INDIA) PRIVATE LIMITED**  
Construction Services Laboratory

For Bureau Veritas (India) Pvt. Ltd \*\*\*\*\*

Authorised Signatory



Bureau Veritas (India) Private Limited  
(Construction Services Laboratory)  
# 33/1178 F1, New # CC 47/1937 & 47/1938  
Kumbalappally Road, Chalikavattom, Vennala  
Cochin - 682 028 • Tel.: +91 484 3320730  
cochin.lab@in.bureauveritas.com

Regd. Off. : Marwah Centre, 6th Floor  
K. Marwah Marg, Off Saki-Vihar Road  
Andheri (East), Mumbai - 400 072. India  
Tel.: +91 22 66956300 Fax: +91 22 66956309  
www.bureauveritas.co.in  
CIN : U74210MH2001PTC134262

Offices/Labs at: Ahmedabad, Bangalore  
Baroda, Bhopal, Chennai, Coimbatore  
Delhi, Goa, Hubli, Indore, Jaipur, Kakinada  
Kandla, Kolkata, Ludhiana, Mangalore  
Nagpur, Nashik, Pune, Raipur, Surat  
Trichy & Visakhapatnam